

<b>Prüfbericht - Nr.:</b> <b>50131691 001</b>		<b>Seite 1 von 43</b>	
<i>Test Report No.:</i>		<i>Page 1 of 43</i>	
<b>Auftraggeber:</b> <i>Client:</i>	Toshiba Carrier (Thailand) Co., Ltd. 144 / 9 Moo 5, Bangkadi Industrial Park, Tivanon Road, Tambol Bangkadi, Amphur Muang, Pathumthani 12000, Thailand		
<b>Gegenstand der Prüfung:</b> <i>Test item:</i>	Air Conditioner (Indoor unit & Outdoor unit)		
<b>Bezeichnung:</b> <i>Identification:</i>	See Page 2 to 4 for details.	<b>Serien-Nr.:</b> <i>Serial No.:</i>	N/A
<b>Wareneingangs-Nr.:</b> <i>Receipt No.:</i>	<b>1203054957</b>	<b>Eingangsdatum:</b> <i>Date of receipt:</i>	5 April 2018
<b>Prüfört:</b> <i>Testing location:</i>	Same as client		
<b>Prüfgrundlage:</b> <i>Test specification:</i>	Annex I of 2006/42/EC the: "Essential health and safety requirements relating to the design and construction of machinery"		
<b>Prüfergebnis:</b> <i>Test Result:</i>	<b>Der Prüfgegenstand entspricht oben genannter Prüfgrundlage(n).</b> <i>The test item passed the test specification(s).</i>		
<b>Prüflaboratorium:</b> <i>Testing Laboratory:</i>	<b>TUV Rheinland Japan Ltd., Yokohama Laboratory,</b> 4-25-2 Kita-Yamata, Tsuzuki-ku, Yokohama 224-0021, Japan		
<b>eprüft/ tested by:</b>		<b>kontrolliert/ reviewed by:</b>	
			
07.08.2018	Prayook Rattanavit / PE	07.08.2018	Loh King Yew / Rev
<b>Datum</b> <i>Date</i>	<b>Name/Stellung</b> <i>Name/Position</i>	<b>Unterschrift</b> <i>Signature</i>	<b>Datum</b> <i>Date</i>
			<b>Name/Stellung</b> <i>Name/Position</i>
			<b>Unterschrift</b> <i>Signature</i>
<b>Sonstiges/ Other Aspects:</b>			
<p>This test report has to be read together with EN 378-2:2016 test report no. 50131691 002  The product is regarded as a partly completed machine in the meaning of Directive 2006/42/EC.  Electric parts and control circuit has been evaluated separately by TÜV Rheinland Thailand. See CB test report, 50102282 001 and 50110389 001  Attachment 1 : CB test certificate and report no.: 50102282 001 and 50110389 001 product information, specification part  Attachment 2 : PED certificate sheet: Certificate No.: 01 202 J/Q 14 0053  Attachment 3 : EMC test report : 50102284 001  Attachment 4 : Manual key pages  Attachment 5 : Risk Assessment Sheet  Attachment 6 : Mechanical test data, Noise measurement data</p>			
<b>Abkürzungen:</b>	<b>P(ass)</b> = entspricht Prüfgrundlage <b>F(ail)</b> = entspricht nicht Prüfgrundlage <b>N/A</b> = nicht anwendbar <b>N/T</b> = nicht getestet	<b>Abbreviations:</b>	<b>P(ass)</b> = passed <b>F(ail)</b> = failed <b>N/A</b> = not applicable <b>N/T</b> = not tested
<b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b>			
<i>This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products.</i>			

## Description of the machine

### System consists of:

Indoor unit and outdoor units of air conditioning system using R32 refrigerant.

The product has been found in compliance with IEC 60335-2-40:2002 +A1:2005 +A2:2005 (refer to Attachment 1 of this report).

The product was re-assessed against the requirements of the Machinery Directive (Annex I of 2006/42/EC).

The product is categorized as a refrigerating appliance of Category I and Category II in accordance with Annex B of EN 378-2:2016. (Refer to test report no. 50131691 002)

All relevant requirements for pressure safety in clause 5.2 and clause 6 of EN 378-2:2016 are fulfilled. Refer to Attachment 2 of this report: PED certificate sheet: Certificate No.: 01 202 J/Q 14 0053.

### Product models under CB Test Report number 50102282 001

The appliances covered by this report are split type air conditioners for cooling and heating modes. They are class I appliances.

Cooling and heating modes are applied by reverse cycle method (no additional heating elements).

Each system consists of indoor and outdoor unit. The indoor units are Hi-wall, Compact 4 Way Cassette, Smart 4 Way Cassette, Slim duct type air conditioner.

The Outdoor units are provided with terminals for connection to supply main by fixed wires and also terminals for connection to indoor units.

The main power is supplied by a single-phase, 3-pole power supply cable (including PE). Outdoor and indoor parts are connected by interconnection cable.

The indoor unit is equipped with a wired remote control unit and infrared wireless battery powered remote control unit. The refrigerant R32 is used in this air conditioner.

#### Indoor unit:

- 1),2) RAV-RM301 series, RAV-RM401 series, RAV-RM561 series,  
RAV-RM801 series, RAV-GM561 series, RAV-GM801 series

#### Outdoor unit:

- 1) RAV-GP561 series, RAV-GP801 seires,
- 2) RAV-GM301 series, RAV-GM401 series, RAV-GM561 series, RAV-GM801 series,  
RAV-GM1101 series, RAV-GM1401 series.
- 3) RAV-GM1101 series, RAV-GM1401 series.

- 1) AC 220 - 240V, 50Hz
  - 2) AC 220 - 240V, 50Hz ; AC 220V, 60Hz
  - 3) AC 380-415V, 3N~, 50Hz ; AC 380V, 3N~, 60Hz.
- IPX4 (outdoor unit); Refrigerant: R32; Class I

Nameplate details refer to CB test report number 50102282 001, Page 5 to 21.  
Product photos refer to CB test report number 50102282 001, Page 206 to 369.

**Product models under CB Test Report number 50110389 001**

The appliances covered by this report are split type air conditioners for cooling and heating modes. They are class I appliances.

Each system consists of indoor and outdoor unit. The indoor units are 4-Way Smart Cassette type air conditioner.

Cooling and heating modes are applied by reverse cycle method (no additional heating elements).

The Outdoor units are provided with terminals for connection to supply main by fixed wires and also terminals for connection to indoor units.

The main power is supplied by a single-phase, 3-pole power supply cable (including PE). Outdoor and indoor parts are connected by interconnection cable.

The indoor unit is equipped with a wired remote control unit.

The refrigerant; R32 is used in this air conditioner.

Outdoor unit:

RAV-GP1101AT-E, RAV-GP1101ATJ-E, RAV-GP1101AT-TR, RAV-GP1401AT-E,  
RAV-GP1401ATJ-E, RAV-GP1401AT-TR

Indoor unit:

RAV-GM1101UT-E, RAV-GM1101UT-TR, RAV-GM1401UT-E, RAV-GM1401UT-TR

AC 220-240V~, 50Hz, Max. 5.20kW, Max. 22.8A,

IPX4 (outdoor unit); Refrigerant: R32; Class I

Nameplate details refer to CB test report number 50110389 001, Page 5 to 12

Product photos refer to CB test report number 50110389 001, Page 136 to 176

**Primary hazards and their protection measures at the machine are:**

Electrical hazard – Comply with the requirements of EN 60335-2-40.

Fire hazard – Comply with the requirement of EN 60335-2-40

Mechanical hazard – Protection by IP2X fan guard

## Table of Contents

<b>1. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS.....</b>	<b>8</b>
1.1 GENERAL REMARKS .....	8
1.1.1 Definitions .....	8
1.1.2 Principles of safety integration.....	9
1.1.3 Materials and products.....	10
1.1.4 Lighting.....	11
1.1.5 Design of machinery to facilitate its handling .....	11
1.1.6 Ergonomics.....	12
1.1.7 Operating positions.....	13
1.1.8 Seating.....	13
1.2 CONTROLS .....	14
1.2.1 Safety and reliability of control systems .....	14
1.2.2 Control devices.....	15
1.2.3 Starting.....	17
1.2.4 Stopping .....	17
1.2.4.1. Normal stop.....	17
1.2.4.2. Operational stop .....	18
1.2.4.3. Emergency stop.....	18
1.2.4.4. Assembly of machinery.....	19
1.2.5 Selection of control or operating modes.....	19
1.2.6 Failure of the power supply .....	20
1.3 PROTECTION AGAINST MECHANICAL HAZARDS.....	21
1.3.1 Risk of loss of stability.....	21
1.3.2 Risk of break-up during operation .....	21
1.3.3 Risks due to falling or ejected objects .....	22
1.3.4 Risks due to surfaces, edges or angles .....	22
1.3.5 Risks related to combined machinery.....	23
1.3.6 Risks relating to variations in operating conditions.....	23
1.3.7 Risks related to moving parts.....	23
1.3.8 Choice of protection against risks arising from moving parts.....	24
1.3.8.1 Moving transmission parts.....	24
1.3.8.2 Moving parts involved in the process .....	24
1.3.9. Risk of uncontrolled movements .....	25
1.4 REQUIRED CHARACTERISTICS OF GUARDS AND PROTECTIVE DEVICES .....	25
1.4.1 General requirement.....	25
1.4.2 Special requirements for guards.....	26
1.4.2.1 Fixed guards.....	26
1.4.2.2 Interlocking movable guards.....	26
1.4.2.3 Adjustable guards restricting access.....	27
1.4.3 Special requirements for protective devices.....	27
1.5 RISKS DUE TO OTHER HAZARDS .....	27
1.5.1 Electricity supply.....	27
1.5.2 Static electricity.....	28
1.5.3 Energy supply other than electricity.....	28
1.5.4 Errors of fitting.....	28
1.5.5 Extreme temperatures.....	29
1.5.6 Fire.....	29
1.5.7 Explosion.....	29
1.5.8 Noise.....	30
1.5.9 Vibrations.....	30
1.5.10 Radiation.....	30
1.5.11 External radiation.....	31
1.5.12 Laser radiation .....	31
1.5.13 Emissions of hazardous materials and substances.....	31
1.5.14 Risk of being trapped in a machine.....	32
1.5.15 Risk of slipping, tripping or falling.....	32
1.5.16 Lightning.....	32
1.6 MAINTENANCE .....	33
1.6.1 Machinery maintenance.....	33
1.6.2 Access to operating positions and servicing points.....	33
1.6.3 Isolation of energy sources .....	33
1.6.4 Operator intervention.....	34
1.6.5 Cleaning of internal parts.....	35
1.7 INFORMATION .....	35
1.7.1 Information and warnings on the machinery.....	35

1.7.1.1 Information and information devices.....	36
1.7.1.2 Warning devices.....	36
1.7.2 Warning of residual risks.....	36
1.7.3 Marking of machinery.....	37
1.7.4 Instructions.....	37
1.7.4.1 General principles for the drafting of instructions.....	38
1.7.4.2 Contents of the instructions.....	39
1.7.4.3 Sales Literature.....	43

## Preliminary Observations

1. The obligations laid down by the essential health and safety requirements apply only when the corresponding hazard exists for the machinery in question when it is used under the conditions foreseen by the manufacturer. In any event, requirements 1.1.2, 1.7.3 and 1.7.4 apply to all machinery covered by this Directive.
2. The essential health and safety requirements laid down in this Directive are mandatory. However, taking into account the state of the art, it may not be possible to meet the objectives set by them. In this case, the machinery must as far as possible be designed and constructed with the purpose of approaching those objectives.
3. The essential health and safety requirements have been grouped according to the hazards which they cover.

Machinery presents a series of hazards which may be indicated under more than one heading in this Annex.

The manufacturer is under an obligation to assess the hazards in order to identify all those which apply to his machine; he must then design and construct it taking account of his assessment.

# 1. Essential Health and Safety Requirements

## 1.1 General Remarks

### 1.1.1 Definitions

*For the purpose of this Annex:*

- (a) hazard means a potential source of injury or damage to health*
- (b) danger zone means any zone within and/or around machinery in which a person is subject to a risk to his health or safety*
- (c) exposed person means any person wholly or partially in a danger zone*
- (d) operator means the person or persons installing, operating, adjusting, maintaining, cleaning, repairing or moving machinery*
- (e) risk means a combination of the probability and the degree of an injury or damage to health that can arise in a hazardous situation;*
- (f) guard means a part of the machinery used specifically to provide protection by means of a physical barrier;*
- (g) protective device means a device (other than a guard) which reduces the risk, either alone or in conjunction with a guard;*
- (h) intended use means the use of machinery in accordance with the information provided in the instructions for use;*
- (i) reasonably foreseeable misuse means the use of machinery in a way not intended in the instructions for use, but which may result from readily predictable human behaviour.*

-

Remarks: Informative paragraph



### 1.1.2 Principles of safety integration

#### *Principles of safety integration*

**P**

*(a) Machinery must be designed and constructed so that it is fitted for its function, and can be operated, adjusted and maintained without putting persons at risk when these operations are carried out under the conditions foreseen but also taking into account any reasonably foreseeable misuse thereof.*

*The aim of measures taken must be to eliminate any risk throughout the foreseeable lifetime of the machinery including the phases of transport, assembly, dismantling, disabling and scrapping.*

Remarks: Principles of safety integration have been taken into account.

*(b) In selecting the most appropriate methods, the manufacturer must apply the following principles, in the order given:*

**P**

*- eliminate or reduce risks as far as possible (inherently safe machinery design and construction),*

*- take the necessary protection measures in relations to risks that cannot be eliminated,*

*- inform users of the residual risks due to any shortcomings of the protection measures adopted, indicate whether any particular training and specify any need to provide personal protection equipment.*

Remarks: Safety methods and design follow the selection criteria as far as feasible for this kind of equipment.

*(c) When designing and constructing machinery, and when drafting the instructions, the manufacturer must envisage not only the intended use the machinery but also any reasonably foreseeable misuse thereof.*

**P**

*The machinery must be designed and constructed to prevent abnormal use if such use would engender a risk. Where appropriate, the instructions must draw the user's attention to ways - which experience has shown might occur - in which the machinery should not be used.*

Remarks: Normal use as well as reasonably foreseeable failures and misuse has been considered.

<i>(d) Machinery must be designed and constructed to take account of the constraints to which the operator is subject as a result of the necessary or foreseeable use of personal protective equipment.</i>	<b>P</b>
---	----------

Remarks: PPEs (safety shoes, helmet and gloves) are required for installation and maintenance. Sufficient information is provided in the manuals.

<i>(e) Machinery must be supplied with all the special equipment and accessories essential to enable it to be adjusted, maintained and used safely.</i>	<b>N/A</b>
---	------------

Remarks: No such special tools.

### 1.1.3 Materials and products

<i>The materials used to construct machinery or products used or created during its use must not endanger persons safety or health.</i>  <i>In particular, where fluids are used, machinery must be designed and constructed to prevent risks due to filling, use, recovery or draining.</i>	<b>P</b>
--	----------

Remarks: The materials used (R32 refrigerant) do not constitute hazards. Hazardous chemicals are not employed.

### 1.1.4 Lighting

*The manufacturer must supply integral lighting suitable for the operations concerned where the absence thereof is likely to cause a risk despite ambient lighting of normal intensity.*

**N/A**

*Machinery must be designed and constructed so that there is no area of shadow likely to cause nuisance, that there is no irritating dazzle and that there are no dangerous stroboscopic effects on moving parts due to the lighting.*

*Internal parts requiring frequent inspection and adjustment and maintenance areas, must be provided with appropriate lighting.*

Remarks: No integral lighting required or provided. Ambient light is considered sufficient for normal operation and maintenance. For servicing, temporary hand-held light will be used.

### 1.1.5 Design of machinery to facilitate its handling

*Design of machinery to facilitate its handling  
Machinery, or each component part thereof, must:*

**P**

- *be capable of being handled and transported safely,*
- *be packaged or designed so that it can be stored safely and without damage.*

Remarks: Sufficient information for transport and storage is provided by labels on the transportation package.

*During the transportation of the machinery and/or its component parts, there must be no possibility of sudden movements or of hazards due to instability as long as the machinery and/or its component parts are handled in accordance with the instructions.*

**N/A**

Remarks: No such possibility.

*Where the weight, size or shape of machinery or its various component parts prevents them from being moved by hand, the machinery or each component part must:*

- *either be fitted with attachments for lifting gear, or*
- *be designed so that it can be fitted with such attachments, or*
- *be shaped in such a way that standard lifting gear can easily be attached.*

**P**

Remarks: The machine will be moved by forklift. Sufficient information is provided by markings on the package and in the Installation manual.

*Where machinery or one of its component parts is to be moved by hand, it must:*

- *either be easily moveable, or*
- *be equipped for picking up and moving safely.*

*Special arrangements must be made for the handling of tools and/or machinery parts which, even if lightweight, could be hazardous in such a way that standard lifting gear can easily be attached.*

**P**

Remarks: Remarks: The Installation manual specifies that. When the air conditioner must be transported by hand, carry it by two or more people

### **1.1.6 Ergonomics**

*Under the intended conditions of use, the discomfort, fatigue and physical and psychological stress faced by the operator must be reduced to the minimum possible, taking into account ergonomic principles such as:*

- *allowing for the variability of the operator's physical dimensions, strength and stamina,*
- *providing enough space for movements of the parts of the operator's body,*
- *avoiding a machine-determined work rate,*
- *avoiding monitoring that requires lengthy concentration,*
- *adapting the man/machinery interface to the foreseeable characteristics of the operators.*

**P**

Remarks: Basic ergonomic principles are considered at design. Sufficient information is provided.

### 1.1.7. Operating positions

*The operating position must be designed and constructed in such a way as to avoid any risk due to exhaust gases and/or lack of oxygen.*

N/A

*If the machinery is intended to be used in a hazardous environment presenting risks to the health and safety of the operator or if the machinery itself gives rise to a hazardous environment, adequate means must be provided to ensure that the operator has good working conditions and is protected against any foreseeable hazards. Where appropriate, the operating position must be fitted with an adequate cabin designed, constructed and/or equipped to fulfil the above requirements. The exit must allow rapid evacuation. Moreover, when applicable, an emergency exit must be provided in a direction which is different from the usual exit.*

Remarks: No operator working with machine during normal operation.

### 1.1.8. Seating

*Where appropriate and where the working conditions so permit, work stations constituting an integral part of the machinery must be designed for the installation of seats.*

N/A

*If the operator is intended to sit during operation and the operating position is an integral part of the machinery, the seat must be provided with the machinery.*

*The operator's seat must enable him to maintain a stable position.*

*Furthermore, the seat and its distance from the control devices must be capable of being adapted to the operator.*

*If the machinery is subject to vibrations, the seat must be designed and constructed in such a way as to reduce the vibrations transmitted to the operator to the lowest level that is reasonably possible. The seat mountings must withstand all stresses to which they can be subjected.*

*Where there is no floor beneath the feet of the operator, footrests covered with a slip-resistant material must be provided.*

Remarks: No such work station.

## 1.2 Controls

### 1.2.1 Safety and reliability of control systems

*Control systems must be designed and constructed in such a way as to prevent hazardous situations from arising. Above all, they must be designed and constructed in such a way that:*

- *they can withstand the intended operating stresses and external influences,*
- *a fault in the hardware or the software of the control system does not lead to hazardous situations,*
- *errors in the control system logic do not lead to hazardous situations,*
- *reasonably foreseeable human error during operation does not lead to hazardous situations.*

**P**

Remarks: Control circuit is evaluated accordingly and complies with IEC 60335-2-40. Refer to Attachment 1 of this report.

*Particular attention must be given to the following points:*

- *the machinery must not start unexpectedly,*
- *the parameters of the machinery must not change in an uncontrolled way, where such change may lead*
- *to hazardous situations,*
- *the machinery must not be prevented from stopping if the stop command has already been given,*
- *no moving part of the machinery or piece held by the machinery must fall or be ejected,*
- *automatic or manual stopping of the moving parts, whatever they may be, must be unimpeded,*
- *the protective devices must remain fully effective or give a stop command,*
- *the safety-related parts of the control system must apply in a coherent way to the whole of an assembly*
- *of machinery and/or partly completed machinery.*
- *For cable-less control, an automatic stop must be activated when correct control signals are not received,*
- *including loss of communication.*

**P**

Remarks: See above.

## 1.2.2 Control devices

<ul style="list-style-type: none"> <li>-</li> <li>- <i>Control devices must be:</i></li> <li>- <i>clearly visible and identifiable, using pictograms where appropriate,</i></li> <li>- <i>positioned in such a way as to be safely operated without hesitation or loss of time and without ambiguity,</i></li> <li>- <i>designed in such a way that the movement of the control device is consistent with its effect,</i></li> <li>- <i>located outside the danger zones, except where necessary for certain control devices such as an emergency stop or a teach pendant,</i></li> <li>- <i>positioned in such a way that their operation cannot cause additional risk,</i></li> <li>- <i>designed or protected in such a way that the desired effect, where a hazard is involved, can only be achieved by a deliberate action,</i></li> <li>- <i>made in such a way as to withstand foreseeable forces; particular attention must be paid to emergency stop devices liable to be subjected to considerable forces.</i></li> <li>- <i>positioned for safe operation without hesitation or loss of time, and without ambiguity,</i></li> <li>- <i>designed so that the movement of the control is consistent with its effect,</i></li> <li>- <i>located outside the danger zones, except for certain controls where necessary, such as emergency stop, console for training of robots,</i></li> <li>- <i>positioned so that their operation can not cause additional risk,</i></li> <li>- <i>designed or protected so that the desired effect, where a risk is involved, cannot occur without an intentional operation,</i></li> <li>- <i>made in such a way as to withstand foreseeable forces; particular attention must be paid to emergency stop devices liable to be subjected to considerable forces.</i></li> </ul>	<p><b>P</b></p>
--	-----------------

Remarks: Sufficient information is provided in the Installation manual.

<p><i>Where a control device is designed and constructed to perform several different actions, namely where there is no one-to-one correspondence, the action to be performed must be clearly displayed and subject to confirmation, where necessary.</i></p> <p><i>Control devices must be so arranged that their layout, travel and resistance to operation are compatible with the action to be performed, taking account of ergonomic principles.</i></p> <p><i>Machinery must be fitted with indicators as required for safe operation. The operator must be able to read them from the control position.</i></p>	<p><b>P</b></p>
--	-----------------

Remarks: See above

*From each control position, the operator must be able to ensure that no-one is in the danger zones, or the control system must be designed and constructed in such a way that starting is prevented while someone is in the danger zone.*

*If neither of these possibilities is applicable, before the machinery starts, an acoustic and/or visual warning signal must be given. The exposed persons must have time to leave the danger zone or prevent the machinery starting up.*

*If necessary, means must be provided to ensure that the machinery can be controlled only from control positions located in one or more predetermined zones or locations.*

*Where there is more than one control position, the control system must be designed in such a way that the use of one of them precludes the use of the others, except for stop controls and emergency stops.*

*When machinery has two or more operating positions, each position must be provided with all the required control devices without the operators hindering or putting each other into a hazardous situation.*

N/A

Remarks: No such danger zone.



### 1.2.3 Starting

*It must be possible to start machinery only by voluntary actuation of a control provided for the purpose.*

**P**

*The same requirement applies:*

- *when restarting the machinery after a stoppage, whatever the cause,*
- *when effecting a significant change in the operating conditions.*

*However, the restarting of the machinery or a change in operating conditions may be effected by voluntary actuation of a device other than the control device provided for the purpose, on condition that this does not*

*lead to a hazardous situation.*

*For machinery functioning in automatic mode, the starting of the machinery, restarting after a stoppage, or a change in operating conditions may be possible without intervention, provided this does not lead to a hazardous situation.*

*Where machinery has several starting control devices and the operators can therefore put each other in danger, additional devices must be fitted to rule out such risks. If safety requires that starting and/or stopping must be performed in a specific sequence, there must be devices which ensure that these operations are performed in the correct order.*

Remarks: In normal operation phase, no special hazard will be occurred by starting. In maintenance phase, Main power will be shut down by circuit breaker with tag-out. Sufficient information is provided in the manual.

### 1.2.4 Stopping

#### 1.2.4.1. Normal stop

*Machinery must be fitted with a control device whereby the machinery can be brought safely to a complete stop.*

**P**

*Each workstation must be fitted with a control device to stop some or all of the functions of the machinery, depending on the existing hazards, so that the machinery is rendered safe.*

*The machinery's stop control must have priority over the start controls.*

*Once the machinery or its hazardous functions have stopped, the energy supply to the actuators concerned must be cut off.*

Remarks: Category 2 stop is accomplished by pressing Start/Stop button.

### 1.2.4.2. Operational stop

*Where, for operational reasons, a stop control that does not cut off the energy supply to the actuators is required, the stop condition must be monitored and maintained.*

**N/A**

Remarks: No such stop control.

### 1.2.4.3. Emergency stop

*Machinery must be fitted with one or more emergency stop devices to enable actual or impending danger to be averted.  
The following exceptions apply:  
Machinery in which an emergency stop device would not lessen the risk, either because it would not reduce the stopping time or because it would not enable the special measures required to deal with the risk to be taken, portable hand-held and/or hand-guided machinery.*

**N/A**

*The device must:*

- *have clearly identifiable, clearly visible and quickly accessible control devices,*
- *stop the hazardous process as quickly as possible, without creating additional risks,*
- *where necessary, trigger or permit the triggering of certain safeguard movements.*

*Once active operation of the emergency stop device has ceased following a stop command, that command must be sustained by engagement of the emergency stop device until that engagement is specifically overridden; it must not be possible to engage the device without triggering a stop command; it must be possible to disengage the device only by an appropriate operation, and disengaging the device must not restart the machinery but only permit restarting.*

*The emergency stop function must be available and operational at all times, regardless of the operating mode.*

*Emergency stop devices must be a back-up to other safeguarding measures and not a substitute for them.*

Remarks: No situations relevant for emergency stop provision. Emergency stop device would not lessen the risk because it would not reduce the stopping time.

#### 1.2.4.4. Assembly of machinery

*In the case of machinery or parts of machinery designed to work together, the machinery must be designed and constructed in such a way that the stop controls, including the emergency stop devices, can stop not only the machinery itself but also all related equipment, if its continued operation may be dangerous.*

**N/A**

Remarks: The machine is intended as stand-alone equipment.

#### 1.2.5 Selection of control or operating modes

*The control or operating mode selected must override all other control or operating modes, with the exception of the emergency stop.*

*If machinery has been designed and constructed to allow its use in several control or operating modes requiring different protective measures and/or work procedures, it must be fitted with a mode selector which can be locked in each position. Each position of the selector must be clearly identifiable and must correspond to a single operating or control mode.*

*The selector may be replaced by another selection method which restricts the use of certain functions of the machinery to certain categories of operator.*

**N/A**

Remarks: No such selection that overrides all other controls.

*If, for certain operations, the machinery must be able to operate with a guard displaced or removed and/or a protective device disabled, the control or operating mode selector must simultaneously:*

- *disable all other control or operating modes,*
- *permit operation of hazardous functions only by control devices requiring sustained action,*
- *permit the operation of hazardous functions only in reduced risk conditions while preventing hazards from linked sequences,*
- *prevent any operation of hazardous functions by voluntary or involuntary action on the machine's sensors.*

*If these four conditions cannot be fulfilled simultaneously, the control or operating mode selector must activate other protective measures designed and constructed to ensure a safe intervention zone.*

*In addition, the operator must be able to control operation of the parts he is working on from the adjustment point.*

**N/A**

Remarks: See above.

### **1.2.6 Failure of the power supply**

*The interruption, the re-establishment after an interruption or the fluctuation in whatever manner of the power supply to the machinery must not lead to dangerous situations.*

*Particular attention must be given to the following points:*

- *the machinery must not start unexpectedly,*
- *the parameters of the machinery must not change in an uncontrolled way when such change can lead to*
- *hazardous situations,*
- *the machinery must not be prevented from stopping if the command has already been given,*
- *no moving part of the machinery or piece held by the machinery must fall or be ejected,*
- *automatic or manual stopping of the moving parts, whatever they may be, must be unimpeded,*
- *the protective devices must remain fully effective or give a stop command.*

**P**

Remarks: Failure of the power supply has been evaluated accordingly. Refer to IEC 60335-2-40 test report, Attachment 1 of this report.

## 1.3 PROTECTION AGAINST MECHANICAL HAZARDS

### 1.3.1 Risk of loss of stability

*Machinery and its components and fittings must be stable enough to avoid overturning, falling or uncontrolled movements during transportation, assembly, dismantling and any other action involving the machinery.*

**P**

*If the shape of the machinery itself or its intended installation does not offer sufficient stability, appropriate means of anchorage must be incorporated and indicated in the instructions.*

Remarks: The machine are fixed appliance. The indoor unit must be install with mounting plate or hanger. Outdoor unit must be fixed on the floor with anchorage bolts. Sufficient information has been provided on installation manual.

### 1.3.2 Risk of break-up during operation

*The various parts of machinery and their linkages must be able to withstand the stresses to which they are subject when used.*

**P**

*The durability of the materials used must be adequate for the nature of the working environment foreseen by the manufacturer or his authorised representative, in particular as regards the phenomena of fatigue, ageing, corrosion and abrasion.*

*The instructions must indicate the type and frequency of inspections and maintenance required for safety reasons. They must, where appropriate, indicate the parts subject to wear and the criteria for replacement.*

*Where a risk of rupture or disintegration remains despite the measures taken, the parts concerned must be mounted, positioned and/or guarded in such a way that any fragments will be contained, preventing hazardous situations.*

Remarks: The materials (steel, plastic, etc.) used in construction are able to withstand the stress of the manufacturing process and are adequate for the installation environment as regards the phenomena of fatigue, aging, corrosion and abrasion.

*Both rigid and flexible pipes carrying fluids, particularly those under high pressure, must be able to withstand the foreseen internal and external stresses and must be firmly attached and/or protected to ensure that no risk is posed by a rupture.*

**P**

Remarks: Pressure test has been conducted. Refer to IEC 60335-2-40 test report, Attachment 2 of this report.

*Where the material to be processed is fed to the tool automatically, the following conditions must be fulfilled to avoid risks to persons:  
When the workpiece comes into contact with the tool, the latter must have attained its normal working condition, when the tool starts and/or stops (intentionally or accidentally), the feed movement and the tool movement must be coordinated.*

**N/A**

Remarks: No such material.

### 1.3.3 Risks due to falling or ejected objects

*Precautions must be taken to prevent risks from falling or ejected objects.*

**P**

Remarks: Sufficient information about fixing bolt and nut provided in the installation manual.

### 1.3.4 Risks due to surfaces, edges or angles

*Insofar as their purpose allows, accessible parts of the machinery must have no sharp edges, no sharp angles and no rough surfaces likely to cause injury.*

**P**

Remarks: Warning label is provided for the aluminium fins (access for maintenance/service). Other exposed surfaces, edges and angles are adequate rounded.

### 1.3.5 Risks related to combined machinery

*Where the machinery is intended to carry out several different operations with manual removal of the piece between each operation (combined machinery), it must be designed and constructed in such a way as to enable each element to be used separately without the other elements constituting a risk for exposed persons.*

**N/A**

*For this purpose, it must be possible to start and stop separately any elements that are not protected.*

Remarks: No such operation required

### 1.3.6 Risks relating to variations in operating conditions

*Where the machinery performs operations under different conditions of use, it must be designed and constructed in such a way that selection and adjustment of these conditions can be carried out safely and reliably.*

**N/A**

Remarks: No such condition exist.

### 1.3.7 Risks related to moving parts

*The moving parts of machinery must be designed and constructed in such a way as to prevent risks of contact which could lead to accidents or must, where risks persist, be fitted with guards or protective devices.*

**P**

*All necessary steps must be taken to prevent accidental blockage of moving parts involved in the work.*

*In cases where, despite the precautions taken, a blockage is likely to occur, the necessary specific protective devices and tools must, when appropriate, be provided to enable the equipment to be safely unblocked. The instructions and, where possible, a sign on the machinery shall identify these specific protective devices and how they are to be used.*

Remarks: Guards in respect of the unit general enclosure are provided for all moving parts. No blockage hazard.

### 1.3.8 Choice of protection against risks arising from moving parts

*Guards or protective devices designed to protect against risks arising from moving parts must be selected on the basis of the type of risk. The following guidelines must be used to help to make the choice.*

**P**

Remarks: See below.

#### 1.3.8.1 Moving transmission parts

*Guards designed to protect persons against the hazards generated by moving transmission parts must be:*

- either fixed guards as referred to in section 1.4.2.1, or
- interlocking movable guards as referred to in section 1.4.2.2.

*Interlocking movable guards should be used where frequent access is envisaged.*

**P**

*Movable guards should be used where frequent access is foreseen.*

Remarks: Fixed guards are used. See clause 1.4.2.1.

#### 1.3.8.2 Moving parts involved in the process

*Guards or protective devices designed to protect persons against the hazards generated by moving parts involved in the process must be:*

- either fixed guards as referred to in section 1.4.2.1, or
- interlocking movable guards as referred to in section 1.4.2.2, or
- protective devices as referred to in section 1.4.3, or
- a combination of the above.

**P**

*However, when certain moving parts directly involved in the process cannot be made completely inaccessible during operation owing to operations requiring operator intervention, such parts must be fitted with: fixed guards or interlocking movable guards preventing access to those sections of the parts that are not used in the work, and adjustable guards as referred to in section 1.4.2.3 restricting access to those sections of the moving parts where access is necessary.*



Remarks: Fixed guards are used. See clause 1.4.2.1.

### 1.3.9. Risk of uncontrolled movements

*When a part of the machinery has been stopped, any drift away from the stopping position, for whatever reason other than action on the control devices, must be prevented or must be such that it does not present a hazard.*

**P**

Remarks: After operating the main circuit breaker to off, all moving parts will be stopped. All tasks are specified to be performed in main disconnecter off condition. Sufficient information is provided in the manuals.

## 1.4 REQUIRED CHARACTERISTICS OF GUARDS AND PROTECTIVE DEVICES

### 1.4.1 General requirement

*Guards and protective devices must:*

- *be of robust construction,*
- *be securely held in place,*
- *not give rise to any additional hazard,*
- *not be easy to by-pass or render non-operational,*
- *be located at an adequate distance from the danger zone,*
- *cause minimum obstruction to the view of the production process, and enable essential work to be carried out on the installation and/or replacement of tools and for maintenance purposes by restricting access exclusively to the area where the work has to be done, if possible without the guard having to be removed or the protective device having to be disabled.*

*In addition, guards must, where possible, protect against the ejection or falling of materials or objects and against emissions generated by the machinery.*

**P**

Remarks: The guards and protection devices provided conform to the above-mentioned requirements.

## 1.4.2 Special requirements for guards

### 1.4.2.1 Fixed guards

*Fixed guards must be fixed by systems that can be opened or removed only with tools.  
Their fixing systems must remain attached to the guards or to the machinery when the guards are removed.  
Where possible, guards must be incapable of remaining in place without their fixings.*

**P**

Remarks: Guards are secured by screws and there are no need to open them neither in normal phase nor in maintenance phase.

### 1.4.2.2 Interlocking movable guards

*Interlocking movable guards must:*

- *as far as possible remain attached to the machinery when open,*
- *be designed and constructed in such a way that they can be adjusted only by means of an intentional action.*

*Interlocking movable guards must be associated with an interlocking device that:*

- *prevents the start of hazardous machinery functions until they are closed and*
- *gives a stop command whenever they are no longer closed.*

*Where it is possible for an operator to reach the danger zone before the risk due to the hazardous machinery functions has ceased, movable guards must be associated with a guard locking device in addition to an interlocking device that:*

- *prevents the start of hazardous machinery functions until the guard is closed and locked, and*
- *keeps the guard closed and locked until the risk of injury from the hazardous machinery functions has ceased.*

*Interlocking movable guards must be designed in such a way that the absence or failure of one of their components prevents starting or stops the hazardous machinery functions*

**N/A**

Remarks: No such guard.

### 1.4.2.3 Adjustable guards restricting access

*Adjustable guards restricting access to those areas of the moving parts strictly necessary for the work must be:*

- *adjustable manually or automatically, depending on the type of work involved, and*
- *readily adjustable without the use of tools.*

**N/A**

Remarks: No adjustable guards used or provided.

### 1.4.3 Special requirements for protective devices

*Protective devices must be designed and incorporated into the control system in such a way that:*

- *moving parts cannot start up while they are within the operator's reach,*
- *persons cannot reach moving parts while the parts are moving, and*
- *the absence or failure of one of their components prevents starting or stops the moving parts.*

*Protective devices must be adjustable only by means of an intentional action.*

**N/A**

Remarks: No such devices.

## 1.5 RISKS DUE TO OTHER HAZARDS

### 1.5.1 Electricity supply

*Where machinery has an electricity supply, it must be designed, constructed and equipped in such a way that all hazards of an electrical nature are or can be prevented.*

*The safety objectives set out in Directive 73/23/EEC shall apply to machinery. However, the obligations concerning conformity assessment and the placing on the market and/or putting into service of machinery with regard to electrical hazards are governed solely by this Directive.*

**P**

Remarks: Hazards of electrical nature have been evaluated accordingly. Refer to Attachment 1 of this report.

### 1.5.2 Static electricity

<i>Machinery must be designed and constructed to prevent or limit the build-up of potentially dangerous electrostatic charges and/or be fitted with a discharging system.</i>	<b>N/A</b>
---	------------

Remarks: No considerable sources of static electricity. The machine frame and relevant parts are grounded.

### 1.5.3 Energy supply other than electricity

<i>Where machinery is powered by source of energy other than electricity, it must be so designed, constructed and equipped as to avoid all potential risks associated with such sources of energy.</i>	<b>P</b>
--	----------

Remarks: Pressure and fluid power sources have been evaluated accordingly. Refer to Attachment 1 of this report.

### 1.5.4 Errors of fitting

<i>Errors likely to be made when fitting or refitting certain parts which could be a source of risk must be made impossible by the design and construction of such parts or, failing this, by information given on the parts themselves and/or their housings. The same information must be given on moving parts and/or their housings where the direction of movement needs to be known in order to avoid a risk. Where necessary, the instructions must give further information on these risks. Where a faulty connection can be the source of risk, incorrect connections must be made impossible by design or, failing this, by information given on the elements to be connected and, where appropriate, on the means of connection.</i>	<b>P</b>
---	----------

Remarks: The fitting will be done by qualified installer. Sufficient information is provided in the installation manual. Error of fitting about machine will not cause a hazard to the user.

### 1.5.5 Extreme temperatures

*Steps must be taken to eliminate any risk of injury arising from contact with or proximity to machinery parts or materials at high or very low temperatures.  
The necessary steps must also be taken to avoid or protect against the risk of hot or very cold material being ejected*

**P**

Remarks: Temperature rise test has been conducted accordingly. No accessible extreme temperature within the machine. Refer to Attachment 1 of this report.

### 1.5.6 Fire

*Machinery must be designed and constructed in such a way as to avoid any risk of fire or overheating posed by the machinery itself or by gases, liquids, dust, vapours or other substances produced or used by the machinery.*

**N/A**

Remarks: Fire hazard due to electrical and chemical (R32) sources have been evaluated according to the requirements of IEC 60335-2-40. A fault of electronic circuit will not render the machine unsafe (Refer to the Attachment 1 of this report.

### 1.5.7 Explosion

*Machinery must be designed and constructed in such a way as to avoid any risk of explosion posed by the machinery itself or by gases, liquids, dust, vapours or other substances produced or used by the machinery.  
Machinery must comply, as far as the risk of explosion due to its use in a potentially explosive atmosphere is concerned, with the provisions of the specific Community Directives.*

**N/A**

Remarks: The product does not produce explosive fluids and is not intended to be installed in explosive atmosphere.

### 1.5.8 Noise

*Machinery must be designed and constructed in such a way that risks resulting from the emission of airborne noise are reduced to the lowest level, taking account of technical progress and the availability of means of reducing noise, in particular at source.*

*The level of noise emission may be assessed with reference to comparative emission data for similar machinery.*

**P**

Remarks: Noise level is measured and was found to be below 50dB(A). (Refer to attachment 6 of this test report.)

### 1.5.9 Vibrations

*Machinery must be designed and constructed in such a way that risks resulting from vibrations produced by the machinery are reduced to the lowest level, taking account of technical progress and the availability of means of reducing vibration, in particular at source.*

*The level of vibration emission may be assessed with reference to comparative emission data for similar machinery.*

**P**

Remarks: Vibration caused by the machine is considered as acceptably low.

### 1.5.10 Radiation

*Undesirable radiation emissions from the machinery must be eliminated or be reduced to levels that do not have adverse effects on persons. Any functional ionising radiation emissions must be limited to the lowest level which is sufficient for the proper functioning of the machinery during setting, operation and cleaning. Where a risk exists, the necessary protective measures must be taken.*

**N/A**

*Any functional non-ionising radiation emissions during setting, operation and cleaning must be limited to levels that do not have adverse effects on persons.*

Remarks: No source of harmful radiation present.

### 1.5.11 External radiation

<i>Machinery must be designed and constructed in such a way that external radiation does not interfere with its operation.</i>	<b>P</b>
--	----------

Remarks: Covered by application of EMC directive. Refer to Attachment 3 of this report.

### 1.5.12 Laser radiation

<i>Where laser equipment is used, the following should be taken into account: Laser equipment on machinery must be designed and constructed in such a way as to prevent any accidental radiation, laser equipment on machinery must be protected in such a way that effective radiation, radiation produced by reflection or diffusion and secondary radiation do not damage health, optical equipment for the observation or adjustment of laser equipment on machinery must be such that no health risk is created by laser radiation.</i>	<b>N/A</b>
--	------------

Remarks: No source of laser radiation provided.

### 1.5.13 Emissions of hazardous materials and substances

<i>Machinery must be designed and constructed in such a way that risks of inhalation, ingestion, contact with the skin, eyes and mucous membranes and penetration through the skin of hazardous materials and substances which it produces can be avoided. Where a hazard cannot be eliminated, the machinery must be so equipped that hazardous materials and substances can be contained, evacuated, precipitated by water spraying, filtered or treated by another equally effective method. Where the process is not totally enclosed during normal operation of the machinery, the devices for containment and/or evacuation must be situated in such a way as to have the maximum effect.</i>	<b>P</b>
---	----------

Remarks: No such materials and substances. Stifling hazard is considered in the risk assessment sheet and manuals.

### 1.5.14 Risk of being trapped in a machine

*Machinery must be designed, constructed or fitted with a means of preventing a person from being enclosed within it or, if that is impossible, with a means of summoning help.*

**N/A**

Remarks: Due to the small footprint of the equipment and its compartments, no full body entry into the machine is possible.

### 1.5.15 Risk of slipping, tripping or falling

*Parts of the machinery where persons are liable to move about or stand must be designed and constructed in such a way as to prevent persons slipping, tripping or falling on or off these parts.  
Where appropriate, these parts must be fitted with handholds that are fixed relative to the user and that enable them to maintain their stability.*

**N/A**

Remarks: No such parts of the machine.

### 1.5.16 Lightning

*Machinery in need of protection against the effects of lightning while being used must be fitted with a system for conducting the resultant electrical charge to earth.*

**P**

Remarks: Sufficient protections are provided considering the installation environment



## 1.6 MAINTENANCE

### 1.6.1 Machinery maintenance

*Adjustment and maintenance points must be located outside danger zones. It must be possible to carry out adjustment, maintenance, repair, cleaning and servicing operations while machinery is at a standstill. If one or more of the above conditions cannot be satisfied for technical reasons, measures must be taken to ensure that these operations can be carried out safely (see section 1.2.5).*

*In the case of automated machinery and, where necessary, other machinery, a connecting device for mounting diagnostic fault-finding equipment must be provided.*

*Automated machinery components which have to be changed frequently must be capable of being removed and replaced easily and safely.*

*Access to the components must enable these tasks to be carried out with the necessary technical means in accordance with a specified operating method.*

**P**

Remarks: For repair activities, the main breaker that must be shut off is stipulated before repair can commence. Sufficient information is provided in the manuals.

### 1.6.2 Access to operating positions and servicing points

*Machinery must be designed and constructed in such a way as to allow access in safety to all areas where intervention is necessary during operation, adjustment and maintenance of the machinery.*

**P**

Remarks: Sufficient information is provided in the installation manual and service manual.

### 1.6.3 Isolation of energy sources.

<p><i>Machinery must be fitted with means to isolate it from all energy sources. Such isolators must be clearly identified.</i></p> <p><i>They must be capable of being locked if reconnection could endanger persons.</i></p> <p><i>Isolators must also be capable of being locked where an operator is unable, from any of the points to which he has access, to check that the energy is still cut off.</i></p> <p><i>In the case of machinery capable of being plugged into an electricity supply, removal of the plug is sufficient, provided that the operator can check from any of the points to which he has access that the plug remains removed.</i></p> <p><i>After the energy is cut off, it must be possible to dissipate normally any energy remaining or stored in the circuits of the machinery without risk to persons.</i></p> <p><i>As an exception to the requirement laid down in the previous paragraphs, certain circuits may remain connected to their energy sources in order, for example, to hold parts, to protect information, to light interiors, etc. In this case, special steps must be taken to ensure operator safety.</i></p>	<b>N/A</b>
--	------------

Remarks: Main breaker will be prepared by the installer. Sufficient information of electrical wiring, rating and safety working step is provided in the Installation / Maintenance manuals.

### 1.6.4 Operator intervention

<p><i>Machinery must be so designed, constructed and equipped that the need for operator intervention is limited.</i></p> <p><i>If operator intervention cannot be avoided, it must be possible to carry it out easily and safely</i></p>	<b>P</b>
---	----------

Remarks: Operator intervention is limited. Where required, operator intervention can be carried out easily and in safety.

### 1.6.5 Cleaning of internal parts

<i>The machinery must be designed and constructed in such a way that it is possible to clean internal parts which have contained dangerous substances or preparations without entering them; any necessary unblocking must also be possible from the outside. If it is impossible to avoid entering the machinery, it must be designed and constructed in such a way as to allow cleaning to take place safely.</i>	<b>P</b>
---	----------

Remarks: No such dangerous substances. During cleaning, the main disconnecting device of the equipment has to be switched off. Sufficient information is provided in the manual.

## 1.7 INFORMATION

### 1.7.1 Information and warnings on the machinery

<i>Information and warnings on the machinery should preferably be provided in the form of readily understandable symbols or pictograms.</i>  <i>Any written or verbal information and warnings must be expressed in an official Community language or languages, which may be determined in accordance with the Treaty by the Member State in which the machinery is placed on the market and/or put into service and may be accompanied, on request, by versions in any other official Community language or languages understood by the operators.</i>	<b>P</b>
--	----------

Remarks: Flammable refrigerant warning label has been install on the machine.

### 1.7.1.1 Information and information devices

*The information needed to control machinery must be provided in a form that is unambiguous and easily understood. It must not be excessive to the extent of overloading the operator.*

**P**

*Visual display units or any other interactive means of communication between the operator and the machine must be easily understood and easy to use.*

Remarks: Appropriate symbols and markings are provided on the remote controller. They are easily understandable.

### 1.7.1.2 Warning devices

*Where the health and safety of persons may be endangered by a fault in the operation of unsupervised machinery, the machinery must be equipped in such a way as to give an appropriate acoustic or light signal as a warning.*

**N/A**

*Where machinery is equipped with warning devices these must be unambiguous and easily perceived.*

*The operator must have facilities to check the operation of such warning devices at all times.*

*The requirements of the specific Community Directives concerning colours and safety signals must be complied with..*

Remarks: No such devices are provided or considered necessary

### 1.7.2 Warning of residual risks

*Where risks remain despite the inherent safe design measures, safeguarding and complementary protective measures adopted, the necessary warnings, including warning devices, must be provided.*

**P**

Remarks: Warning labels are provided. Sufficient information is provided in the manuals.

### 1.7.3 Marking of machinery

*All machinery must be marked visibly, legibly and indelibly with the following minimum particulars:*

- *the business name and full address of the manufacturer and, where applicable, his authorised representative,*
- *designation of the machinery,*
- *the CE Marking (see Annex III),*
- *designation of series or type,*
- *serial number, if any,*
- *the year of construction, that is the year in which the manufacturing process is completed.*

*It is prohibited to pre-date or post-date the machinery when affixing the CE marking.*

*Furthermore, machinery designed and constructed for use in a potentially explosive atmosphere must be marked accordingly.*

*Machinery must also bear full information relevant to its type and essential for safe use. Such information is subject to the requirements set out in section 1.7.1.*

*Where a machine part must be handled during use with lifting equipment, its mass must be indicated legibly, indelibly and unambiguously.*

**P**

Remarks: Nameplate includes: Manufacturer name, address, authorised representative (Toshiba Carrier UK Ltd.), authorised representative address, the CE Marking, Machine Type, Serial No., year of manufacture, electrical ratings.

### 1.7.4 Instructions

*All machinery must be accompanied by instructions in the official Community language or languages of the Member State in which it is placed on the market and/or put into service.*

*The instructions accompanying the machinery must be either Original instructions or a Translation of the original instructions, in which case the translation must be accompanied by the original instructions.*

*By way of exception, the maintenance instructions intended for use by specialised personnel mandated by the manufacturer or his authorised representative may be supplied in only one Community language which the specialised personnel understand.*

*The instructions must be drafted in accordance with the principles set out below.*

**P**

Remarks: Original Instructions (Installation manual and service manual) is provided in English.

#### 1.7.4.1 General principles for the drafting of instructions

*(a) The instructions must be drafted in one or more official Community languages. The words Original instructions must appear on the language version(s) verified by the manufacturer or his authorised representative.*

**P**

Remarks: Original Instructions (Installation manual and service manual) are provided in English. 'Original instructions' is marked on the manuals.

*(b) Where no Original instructions exist in the official language(s) of the country where the machinery is to be used, a translation into that/those language(s) must be provided by the manufacturer or his authorised representative or by the person bringing the machinery into the language area in question. The translations must bear the words Translation of the original instructions.*

**P**

Remarks: Translations are provided by manufacturer.

*(c) The contents of the instructions must cover not only the intended use of the machinery but also take into account any reasonably foreseeable misuse thereof.*

**P**

Remarks: Sufficient information is provided.

*(d) In the case of machinery intended for use by non-professional operators, the wording and layout of the instructions for use must take into account the level of general education and acumen that can reasonably be expected from such operators.*

**N/A**

Remarks: In normal operation phase, there are no special hazards by nonprofessional operators. In maintenance and service, Toshiba Carrier described the necessary qualification of personnel.

### 1.7.4.2 Contents of the instructions

*Each instruction manual must contain, where applicable, at least the following information:*

**P**

Remarks: see below.

*(a) the business name and full address of the manufacturer and of his authorised representative;*

**P**

Remarks: Provided on the Installation manual.

*(b) the designation of the machinery as marked on the machinery itself, except for the serial number (see section 1.7.3);*

**P**

Remarks: Provided on the cover page of the manuals.

*(c) the EC declaration of conformity, or a document setting out the contents of the EC declaration of conformity, showing the particulars of the machinery, not necessarily including the serial number and the signature;*

**P**

Remarks: Provided.

*(d) a general description of the machinery;*

**P**

Remarks: Provided on the Installation manual.

*(e) the drawings, diagrams, descriptions and explanations necessary for the use, maintenance and repair of the machinery and for checking its correct functioning;*

**P**

Remarks: Provided.

*(f) a description of the workstation(s) likely to be occupied by operators;*

**N/A**

Remarks: Not associated with the machine safety design.

*(g) a description of the intended use of the machinery;*

**P**

Remarks: Provided.

*(h) warnings concerning ways in which the machinery must not be used that experience has shown might occur;*

**P**

Remarks: Provided.

*(i) assembly, installation and connection instructions, including drawings, diagrams and the means of attachment and the designation of the chassis or installation on which the machinery is to be mounted;*

**P**

Remarks: Provided.

*(k) instructions for the putting into service and use of the machinery and, if necessary, instructions for the training of operators;*

**P**

Remarks: Provided.

*(l) information about the residual risks that remain despite the inherent safe design measures, safeguarding*

**P**

Remarks: Provided.

*(m) instructions on the protective measures to be taken by the user, including, where appropriate, the personal protective equipment to be provided;*

**P**

Remarks: Provided.

*(n) the essential characteristics of tools which may be fitted to the machinery;*

**P**



Remarks: Provided.

*(o) the conditions in which the machinery meets the requirement of stability during use, transportation, assembly, dismantling when out of service, testing or foreseeable breakdowns;*

**P**

Remarks: Provided.

*(p) instructions with a view to ensuring that transport, handling and storage operations can be made safely, giving the mass of the machinery and of its various parts where these are regularly to be transported separately;*

**P**

Remarks: Provided.

*(q) the operating method to be followed in the event of accident or breakdown; if a blockage is likely to occur, the operating method to be followed so as to enable the equipment to be safely unblocked;*

**P**

Remarks: Provided.

*(r) the description of the adjustment and maintenance operations that should be carried out by the user and the preventive maintenance measures that should be observed;*

**P**

Remarks: Provided.

*(s) instructions designed to enable adjustment and maintenance to be carried out safely, including the protective measures that should be taken during these operations;*

**P**

Remarks: Provided.

*(t) the specifications of the spare parts to be used, when these affect the health and safety of operators;*

**P**

Remarks: Provided.

<p><i>(u) the following information on airborne noise emissions:</i></p> <ul style="list-style-type: none"> <li>- <i>the A-weighted emission sound pressure level at workstations, where this exceeds 70 dB(A); where this level does not exceed 70 dB(A), this fact must be indicated,</i></li> <li>- <i>the peak C-weighted instantaneous sound pressure value at workstations, where this exceeds 63 Pa (130 dB in relation to 20 Pa),</i></li> <li>- <i>the A-weighted sound power level emitted by the machinery, where the A-weighted emission sound pressure level at workstations exceeds 80 dB(A).</i></li> </ul> <p><i>These values must be either those actually measured for the machinery in question or those established on the basis of measurements taken for technically comparable machinery which is representative of the machinery to be produced.</i></p> <p><i>In the case of very large machinery, instead of the A-weighted sound power level, the A-weighted emission sound pressure levels at specified positions around the machinery may be indicated.</i>  <i>Where the harmonised standards are not applied, sound levels must be measured using the most appropriate method for the machinery.</i></p> <p><i>Whenever sound emission values are indicated the uncertainties surrounding these values must be specified. The operating conditions of the machinery during measurement and the measuring methods used must be described.</i></p> <p><i>Where the workstation(s) are undefined or cannot be defined, A-weighted sound pressure levels must be measured at a distance of 1 metre from the surface of the machinery and at a height of 1,6 metres from the floor or access platform. The position and value of the maximum sound pressure must be indicated.</i></p> <p><i>Where specific Community Directives lay down other requirements for the measurement of sound pressure levels or sound power levels, those Directives must be applied and the corresponding provisions of this section shall not apply;</i></p>	<p><b>P</b></p>
---	-----------------

Remarks: Provided in the maintenance manual.

<p><i>(v) where machinery is likely to emit non-ionising radiation which may cause harm to persons, in particular persons with active or non-active implantable medical devices, information concerning the radiation emitted for the operator and exposed persons.</i></p>	<p><b>N/A</b></p>
---	-------------------

Remarks: No such radiation

### 1.7.4.3 Sales Literature

*Sales literature describing the machinery must not contradict the instructions as regards health and safety aspects. Sales literature describing the performance characteristics of machinery must contain the same information on emissions as is contained in the instructions.*

**P**

Remarks: Acoustic noise emission data is provided in the sales literature.

**Chapter 2** not applicable  
**Chapter 3** not applicable  
**Chapter 4** not applicable  
**Chapter 5** not applicable  
**Chapter 6** not applicable

## END OF TEST REPORT